SIDEWALK (EXISTING)

SIDEWALK (PROPOSED)

TREE/SHRUB REMOVAL
TREE/SHRUB TO REMAIN

TRUNCATED DOME PANEL

WATER VALVE



- * REMOVE & RE-INSTALL 4' SIDEWALK (KEEP DIVORCED)
- * ANY DISTURBED SOD WILL BE REPLACED
- * DRIVEWAYS WILL BE EXTENDED TO 14X10, IF GREATER THAN STANDARD THEN WE WILL PROVIDE EXISTING
- * WALKWAYS WILL BE RATHER PRESERVED (TO SOME EXTENT) OR REPLACED BASED ON CONDITION
- * ANY RÉTAINING WALLS WILL ATTEMPT TO PRESERVE (BASED ON CURRENT CONDITION)

GENERAL NOTES

- CONCRETE SHALL ACHIEVE A MINIMUM OF 3000 P.S.I. 28 DAY STRENGTH.
- REINFORCEMENT STEEL SHALL CONFORM TO ATM A-615 GRADE 60 & 2" COVER UNLESS NOTED.
- 3. EXPOSED CONCRETE SURFACES SHALL BE SMOOTH FINISHED.

 4. ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
- 4. ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH. 5. ALL EXPOSED CONCRETE CORNERS OR EDGES TO BE CHAMFERED 3/4"
- OVERLAPPING OF BARS SHALL BE 30 DIAMETERS OR 18 INCHES WHICH EVER IS GREATER.

UTILITY NOTE

UTILITIES SHOWN ON THE PLANS ARE FROM THE BEST INFORMATION SOURCES AVAILABLE AT THE TIME OF DESIGN, BUT MAY NOT REPRESENT ALL EXISTING UTILITIES ON THE SITE. THE CONTRACTOR WILL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES, WHETHER OR NOT THEY ARE SHOWN ON THE PLANS. THE CONTRACTOR SHALL UNCOVER EXISTING UTILITIES PRIOR TO CONSTRUCTION AND VERIFY SIZE, GRADE, AND LOCATION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DEVIATIONS FROM THE PLANS PRIOR TO BEGINNING CONSTRUCTION. ANY DAMAGE TO EXISTING UTILITIES, WHETHER OR NOT SHOWN ON THE PLANS, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR AT HIS EXPENSE. DUE TO FEDERAL REGULATIONS TITLE 493, PART 192.171 CPS MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANT GAS VALVES IN THE PROJECT AREA.

SIDEWALK (PROPOSED)

TREE/SHRUB REMOVAL
TREE/SHRUB TO REMAIN

TRUNCATED DOME PANEL

WATER VALVE





- * REMOVE & RE-INSTALL 4' SIDEWALK (KEEP DIVORCED)
- * ANY DISTURBED SOD WILL BE REPLACED
- * DRIVEWAYS WILL BE EXTENDED TO 14X10, IF GREATER THAN STANDARD THEN WE WILL PROVIDE EXISTING
- * WALKWAYS WILL BE RATHER PRESERVED (TO SOME EXTENT) OR REPLACED BASED ON CONDITION
- * ANY RETAINING WALLS WILL ATTEMPT TO PRESERVE (BASED ON CURRENT CONDITION)

<u>GENERAL NOTES</u>

- CONCRETE SHALL ACHIEVE A MINIMUM OF 3000 P.S.I. 28 DAY STRENGTH.
- 2. REINFORCEMENT STEEL SHALL CONFORM TO ATM A-615 GRADE 60 & 2" COVER UNLESS NOTED.
- 3. EXPOSED CONCRETE SURFACES SHALL BE SMOOTH FINISHED.

 4. ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
- ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
 ALL EXPOSED CONCRETE CORNERS OR EDGES TO BE CHAMFERED 3/4".
- OVERLAPPING OF BARS SHALL BE 30 DIAMETERS OR 18 INCHES WHICH EVER IS GREATER.

UTILITY NOTE

UTILITIES SHOWN ON THE PLANS ARE FROM THE BEST INFORMATION SOURCES AVAILABLE AT THE TIME OF DESIGN, BUT MAY NOT REPRESENT ALL EXISTING UTILITIES ON THE SITE. THE CONTRACTOR WILL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES, WHETHER OR NOT THEY ARE SHOWN ON THE PLANS. THE CONTRACTOR SHALL UNCOVER EXISTING UTILITIES PRIOR TO CONSTRUCTION AND VERIFY SIZE, GRADE, AND LOCATION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DEVIATIONS FROM THE PLANS PRIOR TO BEGINNING CONSTRUCTION. ANY DAMAGE TO EXISTING UTILITIES, WHETHER OR NOT SHOWN ON THE PLANS, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR AT HIS EXPENSE. DUE TO FEDERAL REGULATIONS TITLE 493, PART 192.171 CPS MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANT GAS VALVES IN THE PROJECT AREA.

- **LEGEND** ATT TELECOM BOX
 - CURB (REMOVE/REPLACE)

CURB (EXISTING)

- GFBR
- SANITARY SEWER MANHOLE
- TREE/SHRUB REMOVAL TREE/SHRUB TO REMAIN
- TRUNCATED DOME PANEL
- WATER METER



- REMOVE & RE-INSTALL 4' SIDEWALK (KEEP DIVORCED)
- ANY DISTURBED SOD WILL BE REPLACED
- DRIVEWAYS WILL BE EXTENDED TO 14X10, IF GREATER THAN STANDARD THEN WE WILL PROVIDE EXISTING
- WALKWAYS WILL BE RATHER PRESERVED (TO SOME EXTENT) OR REPLACED BASED ON CONDITION
- ANY RETAINING WALLS WILL ATTEMPT TO PRESERVE (BASED ON CURRENT CONDITION)

GENERAL NOTES

- CONCRETE SHALL ACHIEVE A MINIMUM OF 3000 P.S.I. 28 DAY STRENGTH.
- REINFORCEMENT STEEL SHALL CONFORM TO ATM A-615 GRADE 60 & 2" COVER UNLESS NOTED.
- 3. EXPOSED CONCRETE SURFACES SHALL BE SMOOTH FINISHED.

 4. ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
- ALL EXPOSED CONCRETE CORNERS OR EDGES TO BE CHAMFERED 3/4"
- 6. OVERLAPPING OF BARS SHALL BE 30 DIAMETERS OR 18 INCHES WHICH EVER IS GREATER.

UTILITY NOTE

UTILITIES SHOWN ON THE PLANS ARE FROM THE BEST INFORMATION SOURCES AVAILABLE AT THE TIME OF DESIGN, BUT MAY NOT REPRESENT ALL EXISTING UTILITIES ON THE SITE. THE CONTRACTOR WILL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES, WHETHER OR NOT THEY ARE SHOWN ON THE PLANS. THE CONTRACTOR SHALL UNCOVER EXISTING UTILITIES PRIOR TO CONSTRUCTION AND VERIFY SIZE, GRADE, AND LOCATION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DEVIATIONS FROM THE PLANS PRIOR TO BEGINNING CONSTRUCTION. ANY DAMAGE TO EXISTING UTILITIES, WHETHER OR NOT SHOWN ON THE PLANS, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR AT HIS EXPENSE. DUE TO FEDERAL REGULATIONS TITLE 493, PART 192.171 CPS MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANT GAS VALVES IN THE PROJECT AREA.



Public Works Department

CITY OF SAN ANTONIO SIDEWALKS & SPECIAL PROJS - SIDEWALK CONSTRUCTION -

3 OF 5



- * REMOVE & RE-INSTALL 4' SIDEWALK (KEEP DIVORCED)
- * ANY DISTURBED SOD WILL BE REPLACED
- * DRIVEWAYS WILL BE EXTENDED TO 14X10, IF GREATER THAN STANDARD THEN WE WILL PROVIDE EXISTING
- * WALKWAYS WILL BE RATHER PRESERVED (TO SOME EXTENT) OR REPLACED BASED ON CONDITION
- * ANY RETAINING WALLS WILL ATTEMPT TO PRESERVE (BASED ON CURRENT CONDITION)

GENERAL NOTES

- CONCRETE SHALL ACHIEVE A MINIMUM OF 3000 P.S.I. 28 DAY STRENGTH.
- 2. REINFORCEMENT STEEL SHALL CONFORM TO ATM A-615 GRADE 60 & 2" COVER UNLESS NOTED.
- 3. EXPOSED CONCRETE SURFACES SHALL BE SMOOTH FINISHED.

 4. ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
- ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.
 ALL EXPOSED CONCRETE CORNERS OR EDGES TO BE CHAMFERED 3/4".
- OVERLAPPING OF BARS SHALL BE 30 DIAMETERS OR 18 INCHES WHICH EVER IS GREATER.

UTILITY NOTE


UTILITIES SHOWN ON THE PLANS ARE FROM THE BEST INFORMATION SOURCES AVAILABLE AT THE TIME OF DESIGN, BUT MAY NOT REPRESENT ALL EXISTING UTILITIES ON THE SITE. THE CONTRACTOR WILL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES, WHETHER OR NOT THEY ARE SHOWN ON THE PLANS. THE CONTRACTOR SHALL UNCOVER EXISTING UTILITIES PRIOR TO CONSTRUCTION AND VERIFY SIZE, GRADE, AND LOCATION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DEVIATIONS FROM THE PLANS PRIOR TO BEGINNING CONSTRUCTION. ANY DAMAGE TO EXISTING UTILITIES, WHETHER OR NOT SHOWN ON THE PLANS, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR AT HIS EXPENSE. DUE TO FEDERAL REGULATIONS TITLE 493, PART 192.171 CPS MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANT GAS VALVES IN THE PROJECT AREA.

City of San AntonioPublic Works
Department

CITY OF SAN ANTONIO SIDEWALKS & SPECIAL PROJS - SIDEWALK CONSTRUCTION -

4 OF 5





- ANY DISTURBED SOD WILL BE REPLACED
- DRIVEWAYS WILL BE EXTENDED TO 14X10, IF GREATER THAN STANDARD THEN WE WILL PROVIDE EXISTING
- WALKWAYS WILL BE RATHER PRESERVED (TO SOME * EXTENT) OR REPLACED BASED ON CONDITION
- ANY RETAINING WALLS WILL ATTEMPT TO PRESERVE (BASED ON CURRENT CONDITION)



LEGEND ATT TELECOM BOX ATT CURB (EXISTING) CURB (REMOVE/REPLACE) DRIVEWAY/APPROACH FIRE HYDRANT GFBR GOOGLE FIBER BOX MAIL BOX RETAINING WALL SANITARY SEWER CLEANOUT SANITARY SEWER MANHOLE SIDEWALK (EXISTING) SIDEWALK (PROPOSED) TREE/SHRUB REMOVAL TREE/SHRUB TO REMAIN TRUNCATED DOME PANEL WATER METER WATER VALVE

GENERAL NOTES CONCRETE SHALL ACHIEVE A MINIMUM OF 3000 P.S.I. 28 DAY STRENGTH.

REINFORCEMENT STEEL SHALL CONFORM TO ATM A-615 GRADE 60 & 2" COVER UNLESS NOTED.

EXPOSED CONCRETE SURFACES SHALL BE SMOOTH FINISHED.

ANY IRREGULAR AREA SHALL BE HAND RUBBED TO A SMOOTH FINISH.

ALL EXPOSED CONCRETE CORNERS OR EDGES TO BE CHAMFERED 3/4"

OVERLAPPING OF BARS SHALL BE 30 DIAMETERS OR 18 INCHES WHICH EVER IS GREATER.

UTILITY NOTE

UTILITIES SHOWN ON THE PLANS ARE FROM THE BEST INFORMATION SOURCES AVAILABLE AT THE TIME OF DESIGN, BUT MAY NOT REPRESENT ALL EXISTING UTILITIES ON THE SITE. THE CONTRACTOR WILL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES, WHETHER OR NOT THEY ARE SHOWN ON THE PLANS. THE CONTRACTOR SHALL UNCOVER EXISTING UTILITIES PRIOR TO CONSTRUCTION AND VERIFY SIZE, GRADE, AND LOCATION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DEVIATIONS FROM THE PLANS PRIOR TO BEGINNING CONSTRUCTION. ANY DAMAGE TO EXISTING UTILITIES, WHETHER OR NOT SHOWN ON THE PLANS, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPAIR AT HIS EXPENSE. DUE TO FEDERAL REGULATIONS TITLE 493, PART 192.171 CPS MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANT GAS VALVES IN THE PROJECT AREA.



CITY OF SAN ANTONIO SIDEWALKS & SPECIAL PROJS - SIDEWALK CONSTRUCTION -

5 OF 5